

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

PV Switch-disconnector

Name and address of the applicant

Wenzhou Tosun Electric Co., Ltd.
Room No. 1001, Fortune Center, Station Road, Wenzhou,
325000 Zhejiang
P.R. China

Name and address of the manufacturer

Wenzhou Tosun Electric Co., Ltd.
No.1 Huashan Road, Wenzhou Bridge Industrial Zone,
Baixiang, Yueqing, Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou Tosun Electric Co., Ltd.
No.1 Huashan Road, Wenzhou Bridge Industrial Zone,
Baixiang, Yueqing, Zhejiang
P.R. China

Ratings and principal characteristics

Ui=1200V; Uimp=8kV; -40°C to +85°C; No polarity;
DC-PV2, DC-PV1/DC-21B: Ue=300/600/800/1000/1200V,
Ie=8/10/17/32/40/45A (X=32); Ie=7/9/15/25/40A (X=25);
Ie=6/8/12/16/35A (X=16); Icw=1,0kA, 1s;
IP66 (with enclosure), IP20 (without enclosure)

Trademark / Brand (if any)

TOSUN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SxD-y(x=16, 25, 32)(y=L1, TL, T, PM2, W1, W2, Blank)

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

CN232VEK 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-08-21

Signature:



Wencai Zhang