

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers (MCCB)

Name and address of the applicant

Wenzhou Tosun Electric Co., Ltd.
Room No.1001, Fortune Center, Station Road, Wenzhou, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou Tosun Electric Co., Ltd.
No.1 Huashan Road, Wenzhou Bridge Industrial Zone, Baixiang,
Yueqing, Zhejiang, China

Ratings and principal characteristics

Ue= 220/230/240V~ (1P), 400/415V~ (2P, 3P, 4P), 50/60Hz,
In= 6, 10, 16, 20, 25, 32, 40, 50, 63A, Ref. temperature: 40°C,
Icu= 3kA, Ics= 2,25kA, Utilization category: A,
Uimp= 4kV, Ui= 500V, Suitable for IT system

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

TSB3-63

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

211200278SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature: 

Date: 01 March, 2022

Quan Li